

## **Residential Fire Sprinkler Requirements**

- Existing lots in existing subdivision that were approved prior to August 21, 2006 are not required to have residential fire sprinklers.
- New single-family detached residential subdivisions approved after August 21, 2006 are required residential fire sprinklers when the aggregate number of buildable lots in a subdivision exceeds three (3).
- Single-family detached residential dwellings NOT located within a subdivision are not required to have residential fire sprinklers.